

Your Reliable Guide for Power Solutions

To fulfill our commitment to be the leading supplier in the power generation industry, the Buckeye Power Sales team ensures they are always up-to-date with the current power industry standards as well as industry trends. As a service, our **Information Sheets** are circulated on a regular basis to existing and potential power customers to maintain their awareness of changes and developments in standards, codes and technology within the power industry.

Guide to Generator Set Exhaust Systems

A system designer must consider environmental and performance criteria when sizing and positioning the exhaust system of a generator set. This info sheet is a guide to the issues to be addressed.

Key purpose of the exhaust system: All engine systems have exhaust systems to facilitate:

Safe evacuations of gases: Exhaust gases for safety and environmental concerns should be safely vented to atmosphere for both inside and external locations.

Sound attenuation: Various muffler grades are available to meet different acoustic requirements.

Engine performance: Incorrect exhaust sizing can result in degraded engine performance.

Safe evacuation of exhaust gases: When designing a system the following should be noted:

- To prevent re-circulation of gases into other areas outlets should be located upwind and away from any building and equipment air intakes. Engine exhaust can also be a fire hazard and must never be exhausted adjacent to any combustible material.
- Pipe sleeve or fire proof materials are used when exhaust pipes pass through building material. Local codes should be consulted by the designer. (See diagram one for details)

Sound attenuation: When designing a system the following should be noted:

- Consult local codes for sound level limitations. Generator set manufacturers offer four types of silencers, industrial, residential, critical and hospital for very noise sensitive locations.
- Consult the attenuation curves given for a silencer to ensure it is within code.

Engine performance: The manufacturer can detail the maximum allowable back pressure or restriction with the system. It is specified as "inches hg". When the back pressure is exceeded, the air-fuel ratio is reduced which results in a drop in fuel economy and power output. The following should be actioned:

- The designer, having the manufacture's data for gas flow (ft³/min) and maximum backpressure, uses a chart (see diagram two for details) to determine the inside diameter of the pipe.
- The exhaust system should be designed as short as possible with a minimum of bends. A 90° pipe bend increases the length of the system and back pressure. (see diagram two)

Exhaust system criteria: The designer of the system should also consider the exhaust factors in the design:

Water in the system: Water can be a by-product of exhaust and enter the system as rain. To prevent water from draining back into the system, slant the horizontal pipe away from the engine and install a water trap at the lowest point. (see diagram three for details) A rain cap should be fitted on exhaust pipes ending in the vertical position.

Flexible exhaust sections: To prevent damage due to vibration and thermal expansion, flexible bellow type sections should be installed. Do not use bellows for required bends and alignment adjustment.

Soot deposits: For environmental and aesthetic reasons consider placement of the exhaust outlet to avoid exhaust gas deposits accumulating on adjacent structures/buildings.

Exhaust structure: The exhaust system weight should be adequately supported and utilize robust material such as Schedule 40 black iron. The systems can be supported by various means but must remain flexible and the weight should never be carried by the engine manifold and/or turbo-charger. Galvanized piping should never be used in an exhaust system. (see diagram three for details)

Wind effect: Consider the prevailing wind at the required locations and position the exhaust outlet to avoid exhaust gases being returned into the generator set installation or entering other structures.

CODES: National Protection Association Code Numbers 99 and 100 are important codes that cover generator exhaust systems. The designer should also consult all applicable local codes.

Diagram one - Exhaust Pipe Thimble Installation




Diagram two - Exhaust System Calculations





Diagram three - Typical Exhaust System Layout



Columbus, OH
 6850 Commerce Court Drive
 P.O. Box 489
 Blacklick OH 43004-0489
 (614) 861-6000
 (800) 523-3587
 (614) 861-2291 fax

Cincinnati, OH
 7782 Service Center Drive
 West Chester, OH 45069
 (513) 755-2323
 (800) 368-7422
 (513) 755-4515 fax

Cleveland, OH
 8465 Tower Drive
 P.O. Box 394
 Twinsburg, OH 44087-0394
 (330) 425-9165
 (800) 966-2825
 (330) 487-0229 fax

Indianapolis, IN
 1229 Indy Place
 Indianapolis, IN 46214
 (317) 271-9661
 (800) 632-0339
 (317) 271-0242 fax



www.buckeyepowersales.com