




MODEL	ENCLOSURE WEIGHT KG [LBS]
STEEL WEATHER	494 [1090]
STEEL SOUND	585 [1290]
ALUMINUM SOUND	300 [660]

NOTE:
ENCLOSURE ONLY MOUNTS TO SKID.
FOR STUB-UP ACCESS DURING INSTALLATION THE
REAR ENCLOSURE PANEL SHOULD BE REMOVED

DIMENSIONS IN [] ARE INCH EQUIVALENTS

IBC/OSHPD ENCLOSURE

180 MODEL 4S15, 4S12X, 4S13X
200 MODEL 4UA9, 4UA13, 4S13X
RECONNECTABLE
IMPROVE MOTOR STARTING (IMS) RECONNECTABLE
& 600V ALTERNATORS
6068HF485 JOHN DEERE TIER III

REV	DATE	ON COMPOSITE DWGS. SEE PART NO. FOR REVISION LEVEL	BY	UNLESS OTHERWISE SPECIFIED - 1) DIMENSIONS ARE IN MILLIMETERS 2) TOLERANCES ARE:	APPROVALS		DATE	TITLE
B	11-16-10	(A-8, A-7, A-6, A-5) 156, 1069, 1422, 646, 391 ADDED [90633]	JOEL	X.XX ± 0.25 X.X ± 1.0 X ANGLES ± 0° 30' MAX.	THIRD ANGLE PROJECTION		2-11-10	POWER SYSTEMS, KOHLER, WI 53044 U.S.A. THIS DRAWING IN DESIGN AND DETAIL IS KOHLER CO. PROPERTY AND MUST NOT BE USED EXCEPT IN CONNECTION WITH KOHLER CO. WORK. ALL RIGHTS OF DESIGN OR INVENTION ARE RESERVED.
C	6-20-11	(A-1) STUB-UP NOTE ADDED [91752]	SAM					
D	12-15-11	(C-2) 494 [1090] WAS 363 [800], 585 [1290] WAS 386 [850] AND 300 [660] WAS 238 [525]. [92432]	GFR					
E	2-7-12	(A-4) 180 & 200 MODEL NOTE UPDATED [92681]	PKD		DRAWN DJV		2-11-10	
F	9-18-12	(B-4) 2065 WAS 2128 [CT24079]	SAM		CHECKED CWF		2-11-10	
G	10-31-12	SHEET 2 WAS SHEET1, ADDED SHEET 1 [CT28612]	CEK		APPROVED RJD		2-11-10	

KOHLER CO.		METRIC	PRO-E
SCALE 0.06 CAD NO.			
DWG NO.			
ADV-7854			
SHEET 2 of 2			D