







MODEL	ENCLOSURE WEIGHT KG [LBS]
STEEL WEATHER	363 [800]
STEEL SOUND	386 [850]
ALUMINIUM SOUND	238 [525]



**NOTE:**

1. IF STANDARD TANK IS ORDERED, ENCLOSURE MOUNTS DIRECTLY TO TANK
2. IF STATE TANK IS ORDERED, TANK MOUNTS BELOW SKID
3. TANK MAY EXTEND BEYOND ENCLOSURE (DISCHARGE END ONLY)
4. FOR STUB-UP ACCESS DURING INSTALLATION THE REAR ENCLOSURE PANEL SHOULD BE REMOVED.



DIMENSIONS IN [ ] ARE IN ENGLISH EQUIVALENTS.

230-300 MODEL  
JOHN DEERE TIER III  
IBC/ OSHPD

REV	DATE	ON COMPOSITE DWGS. SEE PART NO. FOR REVISION LEVEL	BY	UNLESS OTHERWISE SPECIFIED - 1) DIMENSIONS ARE IN MILLIMETERS 2) TOLERANCES ARE:
-	10-24-08	NEW DRAWING [86605]	DJG	X.XX ± 0.25 X.X ± 1.0 X ± 1.5 ANGLES ± 0° 30'
A	3-9-10	(A-8) 200 WAS 'A', (A-7) 4094 WAS 'B', 1965 WAS 'C', (D-4) TABLE REMOVED, (D-3) NEW TABLE ADDED, (D-6) 916 WAS 919, (B-6) 859 WAS 863 [89197]	PKD	SURFACE FINISH MAX.
B	10-7-10	(D-6) 523 WAS 588, (C-6) 761 WAS 713, (B-2) 4121.4 WAS 4100.0 [90099-5]	RJS	THIRD ANGLE PROJECTION
C	3-16-11	(A-8) 260.0 WAS 200.0 [91189]	SAM	APPROVALS DATE
D	6-20-11	(C-3) STUB-UP NOTE ADDED [91752]	SAM	DRAWN DJG 10-24-08
E	10-31-12	SHEET2 WAS SHEET 1, ADDED SHEET 1 [CT28612]	CEK	CHECKED CWF 10-24-08 APPROVED SLJ 10-24-08

**KOHLER CO. METRIC PRO-E**  
POWER SYSTEMS, KOHLER, WI 53044 U.S.A.  
THIS DRAWING IN DESIGN AND DETAIL IS KOHLER CO. PROPERTY AND MUST NOT BE USED EXCEPT IN CONNECTION WITH KOHLER CO. WORK. ALL RIGHTS OF DESIGN OR INVENTION ARE RESERVED.

TITLE  
**DIMENSION PRINT 230-300KW JD**

SCALE 0.06 CAD NO. SHEET 2 of 2  
DWG NO. **ADV-7644**