



The emergence of renewable energy using solar and wind power systems as the primary power source, with batteries used as backup energy storage when wind and solar is not available, is creating a new role for engine driven generator systems. This role is to recharge batteries used for energy storage within renewable energy systems during periods when there is insufficient wind or solar power to ensure the batteries are charged to the level as specified for the system.


1.0 INTRODUCTION

While traditional power sources, such as fossil fuel, hydro-electric, and nuclear power, supply more than 90% of US power requirements, renewable energy over the years has found its place as an primary energy source, with wind providing 7.5%, and solar 1.3%, of the utility power generated in the US during 2017. As the US is a major consumer of power, this means a tremendous amount of energy storage is supporting renewable energy systems, and a new role for engine driven generator systems.

2.0 OTHER ENERGY STORAGE METHODS TO THAT OF LITHIUM-ION BATTERY SYSTEMS:

While currently renewable energy systems extensively use Lithium-ion batteries, other sources of stored energy are:

- 2.1 Mechanical - Uninterrupted Power System (UPS) have used the energy stored in a rotating flywheel to generate power when the utility goes off-line and the standby generator runs up to speed. This method is only practical for short periods measured in seconds.
- 2.2 Compressed Air - Stored compressed air through a turbine blade can be used to generate power. However, it requires a considerable amount of stored compressed air to generate power for any period of time, requiring costly storage vessels.
- 2.3 Thermal Energy - Certain volcanic geographic locations can supply thermal energy, and heat pumps can use stored ground heat energy. While these systems are not time limited they can be very costly to install.



Features of Lithium Iron Phosphate batteries to other types	
Chemistry	Lithium Iron Phosphate
Abbreviation	LFP
Cell Voltage	3.2V
Specific energy Wh/kg	90 - 125
Cycle Life	1000 - 3000
Charge Rate (C rate)	C/2 to 4C, charges to 3.7V
Discharge Time	1C but 30C on some cells; 2.5V cut off
High temp durability environment	High
Thermal runaway temperature	270°C (518°F)
Production Costs	Low
Wh/kg = watt hours per kg	

The installation information provided in this information sheet is informational in nature only, and should not be considered the advice of a properly licensed and qualified electrician or used in place of a detailed review of the applicable National Electric Codes and local codes. Specific questions about how this information may affect any particular situation should be addressed to a licensed and qualified electrician.

2.0 OTHER ENERGY STORAGE METHODS TO THAT OF LITHIUM-ION BATTERY SYSTEM: (CONTINUED):

- 2.4 Hydro Energy - The US already has tapped into most suitable topographical areas large enough to generate hydro-electric power economically for long periods of time.
- 2.5 Tidal Energy - Using the movement of water through major tidal areas to generate power has been considered for many years. Large scale projects would be expensive and it has yet to be implemented.
- 2.6 Stored Battery Energy - Before the introduction of Lithium-ion batteries, Lead-Acid and Nickel Cadmium batteries were the batteries of choice in UPS systems and telecommunication systems. Their use is still extensive, but the advantages of Lithium-ion batteries as a more efficient electrical storage method means renewable energy systems are choosing Lithium-ion.

3.0 THE ADVANTAGES OF LITHIUM-ION BATTERIES:

While the initial costs of Lithium-ion batteries are 1.4 times that of alternative batteries, the total ownership costs (TOC) are driving users and designers of renewable energy systems to Lithium-ion. The characteristics of different batteries can also dictate the size of generator system.

The following are examples of the TOC:

- 3.1 Lighter Weight - Being one third the weight of lead-acid results in less expensive mounting arrangements for large systems.
- 3.2 Low Failure Rate - Much lower failure rate with longer lifespan and lower maintenance requirements (10-year TOC savings of 10 to 30%, with almost non-existent failure).
- 3.3 Reduced Maintenance - Built-in Battery Management System (BMS) providing auto status and fault monitoring, etc. whereas a single bad (defective) battery can take down the entire string of lead-acid batteries.
- 3.4 Longer Lifespan - Up to 15 years (lead-acid have to be replaced every 3-4 years).
- 3.5 Operational Temperature Range - Can operate at temperatures of 86°F (30°C) – almost 10°F higher than lead-acid.
- 3.6 Time to Recharge - Can fully recharge in about 2 hours vs. 24 hours for lead-acid.
- 3.6 Less Environmentally Invasive - One third the carbon footprint of lead-acid.

4.0 RECOMMENDED TYPE OF LITHIUM-ION BATTERIES:

The ideal lithium chemistry to use in UPS batteries for data centers is lithium iron phosphate (LFP) – see Diagram 1 overleaf. Compared to other chemistries, lithium iron phosphate offers the best mix of safety, performance, longevity, and cost effectiveness:

- 4.1 Stable Chemistry:- Lithium iron phosphate is a very stable chemistry making it safer to use as a cathode (cobalt is chemically unstable).
- 4.2 Reduced Thermal Runaway:- Provides significantly reduced chance of thermal runaway. Early versions of Lithium batteries gained a reputation for catching fire, hence the move to lithium-ion.
- 4.3 Rapid Charge and Discharge:- The chemistry permits a very rapid discharge and recharge period without generating too much heat.
- 4.4 Fire Suppression:- Should a fire occur with a LFP battery, it can be extinguished by ordinary water sprinkler system.

5.0 TYPICAL BATTERY STORAGE SYSTEMS UTILIZING ENGINE GENERATOR STANDBY SYSTEM:

Engine driven generator systems are used to recharge battery energy storage systems in a variety of off-utility or micro-grid systems including:

- Wind power - Batteries are the energy storage to sustain power when no wind is available. During excessive periods of no wind, standby generators are used to recharge the batteries.
- Solar Power - As above, but the primary power is solar arrays instead of wind generators.
- Battery Energy Standby to Utility Grid - Some systems utilize batteries as the standby power when the utility is off-line. If the battery storage is insufficient to supply power through extended power-outages, an engine driven generator supplies power to the batteries. The generator installation can be permanent or have a mobile generator connected to the system via a docking station.

6.0 GENERATOR SPECIFICATIONS FOR CHARGING LITHIUM-ION BATTERIES:

The following details specification considerations when applying a generator system to supply power to a battery storage system:

- Alternator - As batteries are DC volts and engine generator systems are AC volts, generator power input to the battery when recharging will be through an AC/DC rectifier. Rectifiers use diodes that can produce harmonics that effect the wave form of the AC power. This can be troublesome for Automatic Voltage Regulators (AVR) controlling a generator, therefore the generator specified should be able to withstand a high component of Silicon Controlled Rectifiers (SCR) loads.
- Auto-Starting - Usually a sensor detects the battery has fallen to a certain ampere hour capacity and a signal is transmitted to a 2-way contact for the generator to automatically start. It will shut down when the sensor detects the battery is fully charged.
- Connection of Generator System - The battery storage system outputs DC power that is fed to an inverter to transform the power to AC. The AC generator is connected to the AC side of the system via a by-pass isolator switch if manual, or Automatic Transfer Switch (ATS) if automatic. (See diagram-one front page)

To fulfill our commitment to be the leading supplier in the power generation industry, the Buckeye Power Sales team ensures they are always up-to-date with the current power industry standards as well as industry trends. As a service, our Information Sheets are circulated on a regular basis to existing and potential power customers to maintain their awareness of changes and developments in standards, codes and technology within the power industry.



CANAL WINCHESTER, OH
8155 Howe Industrial Parkway
Canal Winchester, OH 43110
(614) 751-4515
(866) 889-2628

CINCINNATI, OH
4992 Rialto Road
West Chester, OH 45069
(513) 755-2323
(800) 368-7422

CLEVELAND, OH
8465 Tower Drive
Twinsburg, OH 44087-0394
(330) 425-9165
(800) 966-2825

TOLEDO, OH
12400 Williams Road
Perrysburg, OH 43551
(855) 638-2728

INDIANAPOLIS, IN
1707 S. Franklin Road
Indianapolis, IN 46239
(317) 271-9661
(800) 632-0339

FORT WAYNE, IN
7525 Maplecrest Road #221
Fort Wayne, IN 46835
(855) 638-2721

