




NON-TABLED DIMENSIONS ARE TYPICAL ON ALL TANKS			
TANK & LIFT BASE INFORMATION			
LITERS [GALLONS]	GENSETS	HEIGHT DIM A MM [INCH]	TANK WEIGHT KG [LBS] (NO FUEL)
SLI LIFT BASE	KD2000-2500	SEE NOTE	2307 [5086]
8577 [2266]	KD2000-2500	381 [15]	7412 [16,340]
14130 [3733]	KD2000-2500	559 [22]	8142 [17,952]
16451 [4346]	KD2000-2500	635 [25]	8424 [18,571]

TANK WEIGHT + LIFT BASE
WEIGHT + ENCLOSURE WEIGHT +
GENERATOR SET WEIGHT
(REFERENCE FROM GENERATOR
SET ADV) = TOTAL WEIGHT

KD2000-2500 SL1 ENCLOSURE
AND LIFTING BASE WITH SUB
BASE TANK OPTION

REV	DATE	ON COMPOSITE DWGS. SEE PART NO. FOR REVISION LEVEL	BY	DO NOT SCALE. REFERENCE THE MODEL FOR ALL UNSPECIFIED DIMENSIONS
-	5-8-18	NEW DRAWING [CT188177]	ZJS	UNLESS OTHERWISE SPECIFIED: ALL DIMENSIONS IN MILLIMETERS GENERAL TOLERANCES: X.XX ± 0.25 X.X ± 1.0 SURFACE FINISH X ± 1.5 MAX. ANGLES ± 0°30'
				THIRD ANGLE PROJECTION
				APPROVALS DATE
				DRAWN ZJS 5-8-18
				CHECKED ZJS 5-8-18
				APPROVED DPM 5-8-18
				TITLE
				KOHLER. KOHLER, WISCONSIN 53044 THIS DRAWING IN DESIGN AND DETAIL IS KOHLER CO. PROPERTY AND MUST NOT BE USED EXCEPT IN CONNECTION WITH KOHLER CO. WORK. ALL RIGHTS OF DESIGN OR INVENTION ARE RESERVED.
				DIMENSION PRINT, KD2000-2500 TANK & ENCL
				SCALE NA CAD NO. SHEET of 10
				DWG NO. ADV-9075 D

NOTE: DIMENSIONS IN [] ARE ENGLISH EQUIVALENTS

*WEIGHT INCLUDES ENCLOSURE AND SILENCERS

ALUM. SLI ENCLOSURE WEIGHT KG [LBS]	3732 [8,228]
-------------------------------------	--------------

ALTERNATOR END

RADIATOR END

976 [38]
MEASURED FROM
ENCLOSURE FRONT

RADIATOR FACE

2280 [90]

136 [5]

5229 [206]
ENCLOSURE

5469 [215]
LIFT BASE


B

C

SLI CENTER OF GRAVITY (CG) INFORMATION			
LITERS [GALLONS]	GENSETS	HORIZONTAL C.G. DIM B MM [INCH]	VERTICAL C.G. DIM C MM [INCH]
SLI ENCLOSURE	KD2000-2500	SEE DIM	SEE DIM
SLI LIFT BASE	KD2000-2500	SEE DIM	SEE DIM
8577 [2266]	KD2000-2500	5584 [220]	149 [6]
14130 [3733]	KD2000-2500	5575 [220]	228 [9]
16451 [4346]	KD2000-2500	5570 [219]	263 [10]

SL1 CENTER OF GRAVITY POINTS FOR
ENCLOSURE, LIFT BASE, AND TANK VARIATIONS

REV	DATE	ON COMPOSITE DWGS. SEE PART NO. FOR REVISION LEVEL	BY	DO NOT SCALE. REFERENCE THE MODEL FOR ALL UNSPECIFIED DIMENSIONS	
-	5-8-18	NEW DRAWING [CT188177]	ZJS	UNLESS OTHERWISE SPECIFIED: ALL DIMENSIONS IN MILLIMETERS GENERAL TOLERANCES: X.XX ± 0.25 X.X ± 1.0 X ± 1.5 ANGLES ± 0°30' SURFACE FINISH MAX. THIRD ANGLE PROJECTION	
				APPROVALS DATE DRAWN ZJS 5-8-18 CHECKED ZJS 5-8-18 APPROVED DPM 5-8-18	
				KOHLER. KOHLER, WISCONSIN 53044 THIS DRAWING IN DESIGN AND DETAIL IS KOHLER CO. PROPERTY AND MUST NOT BE USED EXCEPT IN CONNECTION WITH KOHLER CO. WORK. ALL RIGHTS OF DESIGN OR INVENTION ARE RESERVED. TITLE DIMENSION PRINT, KD2000-2500 TANK & ENCL SCALE NA CAD NO. SHEET 2 of 10 DWG NO. ADV-9075 D	



ALTERNATOR END

RADIATOR END

3216 [127]
MEASURED FROM
ENCLOSURE FRONT

RADIATOR FACE

KOHLER

2182
[86]

137
[5]

6016 [237]
LIFT BASE

6695 [264]
ENCLOSURE

E

F





SL1 CENTER OF GRAVITY (CG) INFORMATION			
LITERS [GALLONS]	GENSETS	HORIZONTAL C.G. DIM E MM [INCH]	VERTICAL C.G. DIM F MM [INCH]
SL2 ENCLOSURE	KD2000-2500	SEE DIM	SEE DIM
SL2 LIFT BASE	KD2000-2500	SEE DIM	SEE DIM
8577 [2266]	KD2000-2500	5584 [220]	149 [6]
14130 [3733]	KD2000-2500	5575 [220]	228 [9]
16451 [4346]	KD2000-2500	5570 [219]	263 [10]

SL2 CENTER OF GRAVITY POINTS FOR
ENCLOSURE, LIFT BASE, AND TANK VARIATIONS

REV	DATE	ON COMPOSITE DWGS. SEE PART NO. FOR REVISION LEVEL	BY	DO NOT SCALE. REFERENCE THE MODEL FOR ALL UNSPECIFIED DIMENSIONS	
-	5-8-18	NEW DRAWING [CT188177]	ZJS	UNLESS OTHERWISE SPECIFIED: ALL DIMENSIONS IN MILLIMETERS GENERAL TOLERANCES: X.XX ± 0.25 X.X ± 1.0 X ± 1.5 ANGLES ± 0°30' SURFACE FINISH MAX. THIRD ANGLE PROJECTION	
				APPROVALS DATE SCALE NA CAD NO. SHEET 2 of 10	
				TITLE	
				ADV-9075	

KOHLER.
KOHLER, WISCONSIN 53044
THIS DRAWING IN DESIGN AND DETAIL IS KOHLER
CO. PROPERTY AND MUST NOT BE USED EXCEPT IN
CONNECTION WITH KOHLER CO. WORK. ALL RIGHTS
OF DESIGN OR INVENTION ARE RESERVED.




DIMENSION PRINT,
KD2000-2500 TANK & ENCL



SECTION A-A

KD2000-2500 ELECTRICAL ENCLOSURE & TANK ACCESSORY OPTIONS


REV	DATE	ON COMPOSITE DWGS. SEE PART NO. FOR REVISION LEVEL	BY	DO NOT SCALE. REFERENCE THE MODEL FOR ALL UNSPECIFIED DIMENSIONS
-	5-8-18	NEW DRAWING [CT188177]	ZJS	UNLESS OTHERWISE SPECIFIED: ALL DIMENSIONS IN MILLIMETERS GENERAL TOLERANCES: X.XX ± 0.25 X.X ± 1.0 X ± 1.5 ANGLES ± 0°30'
				SURFACE FINISH MAX.
				THIRD ANGLE PROJECTION
				APPROVALS
				DATE
				DRAWN ZJS 5-8-18
				CHECKED ZJS 5-8-18
				APPROVED DPM 5-8-18
				KOHLER. KOHLER, WISCONSIN 53044 THIS DRAWING IN DESIGN AND DETAIL IS KOHLER CO. PROPERTY AND MUST NOT BE USED EXCEPT IN CONNECTION WITH KOHLER CO. WORK. ALL RIGHTS OF DESIGN OR INVENTION ARE RESERVED.
				TITLE DIMENSION PRINT, KD2000-2500 TANK & ENCL
				SCALE NA CAD NO. SHEET 5 of 10
				DWG NO. ADV-9075



SECTION A-A

KD2000-2500
SL2 ENCLOSURE, AQMD

REV	DATE	ON COMPOSITE DWGS. SEE PART NO. FOR REVISION LEVEL	BY	DO NOT SCALE. REFERENCE THE MODEL FOR ALL UNSPECIFIED DIMENSIONS
-	5-8-18	NEW DRAWING [CT188177]	ZJS	UNLESS OTHERWISE SPECIFIED: ALL DIMENSIONS IN MILLIMETERS GENERAL TOLERANCES: X.XX ± 0.25 X.X ± 1.0 X ± 1.5 ANGLES ± 0°30'
				KOHLER. KOHLER, WISCONSIN 53044 THIS DRAWING IN DESIGN AND DETAIL IS KOHLER CO. PROPERTY AND MUST NOT BE USED EXCEPT IN CONNECTION WITH KOHLER CO. WORK. ALL RIGHTS OF DESIGN OR INVENTION ARE RESERVED.
				TITLE DIMENSION PRINT, KD2000-2500 TANK & ENCL
				APPROVALS DRAWN ZJS 5-8-18 CHECKED ZJS 5-8-18 APPROVED DPM 5-8-18
				DATE 5-8-18 5-8-18 5-8-18
				SCALE NA CAD NO. SHEET 8 of 10
				DWG NO. ADV-9075 D




TANK MOUNTING INFORMATION										
LITERS [GALLONS]	DIMENSION "I"	DIMENSION "J"	DIMENSION "K"	DIMENSION "L"	DIMENSION "M"	DIMENSION "N"	DIMENSION "O"	DIMENSION "P"	DIMENSION "Q"	DIMENSION "R"
8577[2266]	695.5	695.7	948.8	1273.2	779.4	1520.4	693.6	693.5	1880.0	NA
14130[3733]	695.5	1196.9	447.6	1273.2	614.9	1685.0	693.6	693.5	1880.0	NA
16451[4346]	888.5	1003.9	447.6	1273.1	779.3	1520.5	693.6	693.5	683.0	1197.1

TANK LIFT PLATE INFORMATION		
LITERS [GALLONS]	DIMENSION "G" MM [INCHES]	DIMENSION "H" MM [INCHES]
8577 [2266]	2300 [91]	2222 [87]
14130 [3733]	2300 [91]	2222 [87]
16451 [4346]	3576 [141]	2337 [92]

NON-TABLED DIMENSIONS ARE
TYPICAL ON ALL TANKS


MOUNTING AND LIFTING LOCATIONS
4346 GAL. TANK SHOWN
ALSO REFERENCING TANKS:
2263 GAL. & 3733 GAL.

REV	DATE	ON COMPOSITE DWGS. SEE PART NO. FOR REVISION LEVEL	BY	DO NOT SCALE. REFERENCE THE MODEL FOR ALL UNSPECIFIED DIMENSIONS		
-	5-8-18	NEW DRAWING [CT188177]	ZJS	UNLESS OTHERWISE SPECIFIED: ALL DIMENSIONS IN MILLIMETERS GENERAL TOLERANCES: X.XX ± 0.25 X.X ± 1.0 X ± 1.5 ANGLES ± 0°30' SURFACE FINISH MAX. THIRD ANGLE PROJECTION		
				APPROVALS DATE SCALE DWG NO.		
				TITLE DIMENSION PRINT, KD2000-2500 TANK & ENCL SHEET 7 of 10 ADV-9075 D		



KD2000-2500 SL1 ENCLOSURE
LIFTING BASE MOUNTING

REV	DATE	ON COMPOSITE DWGS. SEE PART NO. FOR REVISION LEVEL	BY	DO NOT SCALE. REFERENCE THE MODEL FOR ALL UNSPECIFIED DIMENSIONS
-	5-8-18	NEW DRAWING [CT188177]	ZJS	UNLESS OTHERWISE SPECIFIED: ALL DIMENSIONS IN MILLIMETERS GENERAL TOLERANCES: X.XX ± 0.25 X.X ± 1.0 X ± 1.5 ANGLES ± 0°30'
				THIRD ANGLE PROJECTION
				APPROVALS
				DATE
				DRAWN ZJS 5-8-18
				CHECKED ZJS 5-8-18
				APPROVED DPM 5-8-18
				COHLER, WISCONSIN 53044 THIS DRAWING IN DESIGN AND DETAIL IS KOHLER CO. PROPERTY AND MUST NOT BE USED EXCEPT IN CONNECTION WITH KOHLER CO. WORK. ALL RIGHTS OF DESIGN OR INVENTION ARE RESERVED.
				TITLE DIMENSION PRINT, KD2000-2500 TANK & ENCL
				SCALE NA CAD NO. SHEET 8 of 10
				DWG NO. ADV-9075 D




KD2000-2500 SL2 ENCLOSURE
LIFTING BASE MOUNTING

REV	DATE	ON COMPOSITE DWGS. SEE PART NO. FOR REVISION LEVEL	BY	DO NOT SCALE. REFERENCE THE MODEL FOR ALL UNSPECIFIED DIMENSIONS
-	5-8-18	NEW DRAWING [CT188177]	ZJS	UNLESS OTHERWISE SPECIFIED: ALL DIMENSIONS IN MILLIMETERS GENERAL TOLERANCES: X.XX ± 0.25 X.X ± 1.0 SURFACE FINISH X ± 1.5 MAX. ANGLES ± 0°30'
				THIRD ANGLE PROJECTION
				APPROVALS DATE
				DRAWN ZJS 5-8-18
				CHECKED ZJS 5-8-18
				APPROVED DPM 5-8-18
				TITLE
				KOHLER, WISCONSIN 53044
				THIS DRAWING IN DESIGN AND DETAIL IS KOHLER CO. PROPERTY AND MUST NOT BE USED EXCEPT IN CONNECTION WITH KOHLER CO. WORK. ALL RIGHTS OF DESIGN OR INVENTION ARE RESERVED.
				DIMENSION PRINT, KD2000-2500 TANK & ENCL
				SCALE NA CAD NO. SHEET 3 of 10
				DWG NO. ADV-9075
				D

ALTERNATOR END

RADIATOR END

RADIATOR FACE



NON-TABLED DIMENSIONS ARE TYPICAL ON ALL TANKS

TANK & LIFT BASE INFORMATION					
LITERS [GALLONS]	GENSETS	HEIGHT DIM S MM [INCH]	WEIGHT KG [LBS] (NO FUEL)	HORIZONTAL C.G. DIM T MM [INCH]	VERTICAL C.G. DIM U MM [INCH]
OPEN LIFT BASE	KD2000-2500	SEE DIM	2307 [5086]	SEE DIM	SEE DIM
8577 [2266]	KD2000-2500	381 [15]	7412 [16,340]	5584 [220]	149 [6]
14130 [3733]	KD2000-2500	559 [22]	8142 [17,952]	5575 [220]	228 [9]
16451 [4346]	KD2000-2500	635 [25]	8424 [18,571]	5570 [219]	263 [10]

KD2000-2500 OPEN UNIT
LIFTING BASE WITH SUB
BASE TANK OPTION

TANK WEIGHT + LIFT BASE WEIGHT + GENERATOR SET WEIGHT
(REFERENCE FROM GENERATOR SET ADV) =TOTAL WEIGHT

REV	DATE	ON COMPOSITE DWGS. SEE PART NO. FOR REVISION LEVEL	BY	DO NOT SCALE. REFERENCE THE MODEL FOR ALL UNSPECIFIED DIMENSIONS
-	5-8-18	NEW DRAWING [CT188177]	ZJS	UNLESS OTHERWISE SPECIFIED: ALL DIMENSIONS IN MILLIMETERS GENERAL TOLERANCES: X.XX ± 0.25 X.X ± 1.0 SURFACE FINISH X ± 1.5 MAX. ANGLES ± 0°30'
				THIRD ANGLE PROJECTION
				APPROVALS DATE
				DRAWN ZJS 5-8-18
				CHECKED ZJS 5-8-18
				APPROVED DPM 5-8-18
				TITLE
				KOHLER. KOHLER, WISCONSIN 53044 THIS DRAWING IN DESIGN AND DETAIL IS KOHLER CO. PROPERTY AND MUST NOT BE USED EXCEPT IN CONNECTION WITH KOHLER CO. WORK. ALL RIGHTS OF DESIGN OR INVENTION ARE RESERVED.
				DIMENSION PRINT, KD2000-2500 TANK & ENCL
				SCALE NA CAD NO. SHEET 10 of 10
				DWG NO. ADV-9075
				D