



As covered in a prior information sheet detailing the causes for power outages in the United States, one reason identified was animals with a high percentage being vermin intrusion and damage to the generator system; see figure 1. Nearly 5% of power outages are the result of vermin, particularly when the equipment is installed outdoors. While manufacturers of generator systems provide protection for operators inadvertently touching live circuits and rotating equipment and protection against adverse weather, these protections are no guarantee that vermin can't get inside and cause damage which leads to failure. This information sheet discusses how residential, industrial and commercial generator systems can be protected from animals and the type of damage these animals can create.

1.0 WHAT ANIMALS INVADE GENERATOR SYSTEMS:

Nature has many types of species that can and do harm generator systems for a variety of reasons. In this information sheet we cover the most common invasive species and the damage that is likely to occur. When protecting your generator installation be aware of the following species: (Continued Over).

Protecting Generator Systems from Invasive Species

Residential Generator

Figure 3

Pheromone Trap/Monitor

Figure 2

Bait Trap

Reported Power Outages by Cause

Cause	Count
Animal	173
Faulty Equipment/Human Error	791
Planned	244
Unknown	693
Vehicle Accident	444
Weather/Trees	1159
Over demand	7
Theft/Vandalism	15

Figure 1

The installation information provided in this information sheet is informational in nature only, and should not be considered the advice of a properly licensed and qualified electrician or used in place of a detailed review of the applicable National Electric Codes and local codes. Specific questions about how this information may affect any particular situation should be addressed to a licensed and qualified electrician.

1.1 RODENTS – Rodents cover a variety of types from field mice, voles, to rats. The number one item they hone in on is the generator system’s wiring. All types of rodents, including squirrels, have a tendency to gnaw on wiring installations. Why they do this is not known, but it could be associated with the paraffin in the wax used for lubricating wires in the manufacturing process when the wire is pulled through the insulation. Alternatively, they may be using wiring to sharpen their teeth. Either way, it breaks down wiring insulation causing shorts between various exposed wires.

Rodent damage has been seen in residential, industrial, and commercial installation. Rodents are attracted to the warmth and protection of enclosed areas. During winter months they build nests to seek shelter from the cold. Many generator installations are for standby, and as such are stationary for long periods of time. During these periods nests can be built among wiring bundles and ventilation areas.

In addition to wire gnawing and nesting, rodent droppings are highly corrosive to any metal material within the generator.

1.2 LARGE ANIMALS – Damage from larger animals is mainly due to location. Damage occurs when unfenced installations are damaged when the animal, cow, bear, etc., rubs against enclosures and other components.

1.3 BIRDS – The biggest problem with birds is the building of nests. Most damage from birds occurs in outside installations. Generator enclosures are designed with openings for cooling air, exhaust, and cable connections. Even though enclosures are designed for weather protection, small birds can access small opening to build nests.

Nests within a generator system can result in the following:

- Obstructing ventilation openings for incoming and outgoing coolant air
- Obstructions for radiator coils leading to overheating
- Blocked exhaust vents for lack of performance and fire risk
- Corrosion due to bird excrement

Most evasion of generator systems by birds is internal, but in some areas where big birds nest there is the possibility of a bird building a nest on top of an enclosure to be above ground.

1.4 INSECTS – Mud wasps, bees and spiders have built nests in vents and cooling equipment during a standby generators stationary period.

2.0 INSTALLATIONS SUSCEPTIBLE TO INVASIVE SPECIES DAMAGE:

Animals of many types can be found in most environments that generator systems are installed in, but the most susceptible are outside installations. The following installations are considered susceptible to damage from invasive species:

2.1 RESIDENTIAL – Generator service providers report many problems with residential generators installed adjacent to the home from rodent-type damage. The generator sits idle for long periods of time for damage to build up. The worst time is in the spring when many creatures become active and start to seek out nesting locations.

2.1 REMOTE COMMERCIAL AND INDUSTRIAL APPLICATIONS – Network service providers to telecommunication companies having many remote locations, report failures from vermin nesting in equipment. Part of any seasonal planned maintenance program should include inspections for any species invasion, particularly just before winter and the start of spring.

3.0 HOW TO MITIGATE GENERATOR DAMAGE FROM INVASIVE SPECIES:

Your authorized generator distributor is very familiar with the damage invasive species can inflict on a generator system. When rodents, birds, etc. invasion is discovered, an authorized generator distributor should be called to thoroughly check out the system for any damage. If there is a reason for failure, they can repair any damage and put in place procedures to ensure it doesn’t occur again. The plan is to remove rodents and other creatures ensuring they are kept out, these plans include:

3.1 RODENT DISCOURAGEMENT – Make sure any openings have mesh, small enough to stop access but not too small to hinder functions such as ventilation. The next step is to place rodent bait stations around and near the installation to discourage them from entering the enclosure or any other part of the generator. *See figure 2*

As a second line of defense, strategically place bait inside the equipment, this will discourage nest building if rodents do access the interior. Another line of defense to attract rodents away from the generator system is to install pheromone monitor boards inside the enclosure or just under it. *See figure 3*

3.2 LARGE ANIMALS – In rural remote installations and farming environments, an outside installation should be fenced to prevent inquisitive creatures from damaging equipment.

3.3 BIRD DISCOURAGEMENT – Openings for ventilation, wire access, and service should be covered in areas where birds are known to nest. Again, meshing of openings cannot impede the required ventilation, so consult with your service distributor.

3.4 INSECTS – Meshing to prevent insects in areas of ventilation will prove to be restrictive to airflow. It is important to monitor invasion by insects, particularly in cooling items such as radiator coils and inside control panels.

4.0 PLANNED GENERATOR SERVICE PROGRAMS:

Your authorized generator distributor can offer a planned service program to ensure the generator is ready to start when required. These programs include certain maintenance items and part of the program will also inspect the unit for invasive species.

If the presence of an invasion like rodents is found, it is important that the generator set is run up to speed and all functions are checked to ensure there are no faults such as chewed through wires. Remember to consult with your authorized generator distributor.

To fulfill our commitment to be the leading supplier in the power generation industry, the Buckeye Power Sales team ensures they are always up-to-date with the current power industry standards as well as industry trends. As a service, our Information Sheets are circulated on a regular basis to existing and potential power customers to maintain their awareness of changes and developments in standards, codes and technology within the power industry.



CANAL WINCHESTER, OH
8155 Howe Industrial Parkway
Canal Winchester, OH 43110
(614) 751-4515
(866) 889-2628

CINCINNATI, OH
4992 Rialto Road
West Chester, OH 45069
(513) 755-2323
(800) 368-7422

CLEVELAND, OH
8465 Tower Drive
Twinsburg, OH 44087-0394
(330) 425-9165
(800) 966-2825

TOLEDO, OH
27100 Oakmead Dr.
Perrysburg, OH 43551
(855) 638-2728

CHICAGO, IL
1308 Marquette Drive
Romeoville, IL 60446
(630) 914-3000

INDIANAPOLIS, IN
1707 S. Franklin Road
Indianapolis, IN 46239
(317) 271-9661
(800) 632-0339

FORT WAYNE, IN
7525 Maplecrest Road #221
Fort Wayne, IN 46835
(855) 638-2721

